

Weekly report from Hideaway bay 2-26-22

- Piper Fire came to Hideaway and did a 5 year test of the alarm system and sprinkler systems on Thursday and Friday. Fire alarm pull stations were broken in the process which made the alarm system go into a “Trouble” mode. I asked the people from Piper to fix the problem when they returned on Friday. They did not fix it, but were going to report it. I learned that they entered G-6 while I was tied up on the ferry even though I told them that they could not enter unless I was with them. I called Piper over the weekend to report the trouble and they assured me that someone would be out first thing on Monday 2-28-22. Nobody showed up. I had to reset the alarm system at 3 buildings throughout the weekend. I called one of the managers and they had no record of the trouble ticket that I had generated. I found 2 new fire alarm panels in the back closet in the library. I am in hopes that they can be used to fix the alarm problem for good. As a retired Firefighter, I have to say that I am uncomfortable with the current system. This has been reported for years
- The decking on the BBQ area has been repaired
- Martin's came to island to pump out the sewer system, but has not been back to complete the process
- I have not heard back from Abbott Construction about the ramp on the mainland dock. I placed a call to them and I'm waiting to hear back.
- I have not heard from Richard Leyton about the work he promised
-